




CITEL



Type 1+2+3 AC surge protector

DACN1-25VGS-10-760

- Type 1 + 2+3 AC surge protector
- VG Technology
- In: 35 kA
- Iimp: 25 kA on 10/350µs impulse
- No leakage current
- Unpluggable module for each phase
- Remote signaling
- Optimized to TOV
- EN 61643-11, IEC 61643-11 complied



Electrical Characteristics		
SPD type	IEC	1+2+3
Network		Up to 690 Vac single-phase
Max. AC operating voltage	Uc	760 Vac
Max. load current @25°C	IL	100 A
Temporary Over Voltage (TOV) Characteristics - 5 sec. Without disconnection	UT	1000 Vac withstand
Temporary Over Voltage (TOV) Characteristics - 120 mn Without disconnection or with safety disconnection	UT	1325 Vac disconnection
Residual Current Leakage current to Ground	Ipe	None
Follow current	If	None
Nominal discharge current 15 x 8/20 µs impulses	In	35 kA
Max. discharge current max. withstand @ 8/20 µs by pole	Imax	70 kA
Impulse current by pole max. withstand 10/350µs by pole	Iimp	25 kA
Withstand on Combination waveform IEC 61643-11 Class III test: 1.2/50µs - 8/20µs	Uoc	6 kV
Specific energy by pole max. withstand 10/350 µs	W/R	156 kJ/ohm
Protection level @ In (8/20µs) and @ 6 kV (1,2/50 µs)	Up	2.5 kV
Protection level L/PE @ In (8/20µs)	Up L/PE	2.5 kV
Residual voltage L/PE at 5 kA @ 5 kA (8/20µs)	Up-5kA	1.6 kV
Admissible short-circuit current	Isc cr	50 000 A
Mechanical Characteristics		
Technology		VG Technology (MOV+GSG)
SPD configuration		Single phase
Connection to Network		By screw terminals: 2.5-25mm ² (35mm ² rigid)
Format		1-pole modular box
Mounting		Symmetrical rail 35 mm (EN 60715)
Housing material		Thermoplastic UL94 V-0
Operating temperature	Tu	-40/+85°C
Protection rating		IP20
Failsafe mode		Disconnection from AC network
Disconnection indicator		1 mechanical indicator by pole - Red/Green
Remote signaling of disconnection		Output on changeover contact
Wiring for remote signaling		1.5 mm ² max.
Max. Voltage/Current for remote signaling		250 V / 0.5 A (AC) / 30 V / 3 A (DC)
Dimensions		See diagram - 2TE (EN43880)
Disconnectors		
Thermal disconnecter		Internal
Installation ground fault breaker		Type 'S' or delayed
Back-up protection device		Fuse assembly: SFD1-25S-10 / or Fuses Type gG 315 A
Standards		
Standards compliance		EN 61643-11 / IEC 61643-11
Certification		TUV
Part number		
29221012		

