



EU Declaration of conformity



Company: CITEL

Address: 2, rue Troyon 92310, Sèvres, France

Trade Mark: CITEL

Products: Type 2 compact SPD for DC Network

This is to certify that **DDCxC series**, as follow, products manufactured by Citel are in compliance with:

- **Directive 2011/65/EU** (and delegated directive **2015/863/EU**) on the Restriction of the use Of certain Hazardous Substances in electrical and electronic equipment (RoHS Directive).
- **Low Voltage Directive 2014/35/EU**, of the Council of the European Union

<i>Models</i>	<i>Application</i>
DDC20C-20-24	Compact Type 2 SPD for 12 Vdc Network
DDC20C-20-38	Compact Type 2 SPD for 24 Vdc Network
DDC30C-20-65	Compact Type 2 SPD for 48 Vdc Network
DDC40C-20-100	Compact Type 2 SPD for 75 Vdc Network
DDC40C-20-125	Compact Type 2 SPD for 95 Vdc Network
DDC40C-20-150	Compact Type 2 SPD for 110 Vdc Network
DDC40C-20-180	Compact Type 2 SPD for 130 Vdc Network
DDC40C-20-275	Compact Type 2 SPD for 220 Vdc Network
DDC40C-20-350	Compact Type 2 SPD for 280 Vdc Network
DDC40C-20-460	Compact Type 2 SPD for 350 Vdc Network
DDC20CS-20-24	Compact Type 2 SPD for 12 Vdc Network (remote signaling)
DDC20CS-20-38	Compact Type 2 SPD for 24 Vdc Network (remote signaling)
DDC30CS-20-65	Compact Type 2 SPD for 48 Vdc Network (remote signaling)
DDC40CS-20-100	Compact Type 2 SPD for 75 Vdc Network (remote signaling)
DDC40CS-20-125	Compact Type 2 SPD for 95 Vdc Network (remote signaling)
DDC40CS-20-150	Compact Type 2 SPD for 110 Vdc Network (remote signaling)
DDC40CS-20-180	Compact Type 2 SPD for 130 Vdc Network (remote signaling)



<i>Models</i>	<i>Application</i>
DDC40CS-20-275	Compact Type 2 SPD for 220 Vdc Network (remote signaling)
DDC40CS-20-350	Compact Type 2 SPD for 280 Vdc Network (remote signaling)
DDC40CS-20-460	Compact Type 2 SPD for 350 Vdc Network (remote signaling)

The DDCxC series is in compliance with their related European testing standard:

European standard	Description
EN 50539-11:2013 + EN50539-11:2013/A1:2014	Low-voltage surge protective devices – Part 11: Surge protective devices connected to photovoltaic DC power systems – Requirements and test methods

H.GUICHARD
General Manager
2021-09-20

Authorized signatory for CITEL 2CP
P. Guillaumin
Quality Manager
2021-09-20

CITEL 2 CP S.A.S.
Capital 5 013 500 €
2 rue Troyon
92316 SEVRES CEDEX
Tél. : 01 41 23 50 23
Fax : 01 41 23 50 09
Siren 387 740 095 - APE 2712Z